CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7300-0811:0131
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Federal Signal 2645 Federal Signal Drive, University Park, IL, 60466 Contact: Moloney,Sean (708) 587-3324 (708) 534-4878 Email: smoloney@federalsignal.com
DESIGN:	Model 27XST and FSEX general signaling strobe lights for use in hardous locations: Class I, Division 1, Group C and D; Class I, Division 2, Group A and B; Class II, Group E, F and G; and Class III. Refer to listee's data sheet for additional product description and operational considerations.
RATING:	24, 120, 240VAC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as general visual signaling strobe lights (non-fire alarm) for use with separately listed compatible fire alarm control units. For indoor and outdoor use. Enclosure is rated Type 4X. Not suitable for the hearing impaired applications. Refer to listee's Installation Instruction Manual for details.
NOTES:	

*Rev. 02-03-04

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/25/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division